

No.	Question	City's/Engineer's Answers
1	What is the Brand and model of meters to be replaced/installed?	Most meters being replaced are Badger with some Sensus. All of the replacement meters are Badger.
2	What are the current sizes of meters that needs to be replaced?	5/8" or 3/4" - the replacement meters are all 3/4 inch
3	What materials will contractors need to provide?	Contractor will need to provide their own tools in order to install equipment. See RFP requirements as a plumber is required and they will need to provide their own tools and materials for any repairs needed to be completed.
4	What meters are currently present/to be removed?	Not sure, but the meters are removed from inside the home or in meter pits
5	Are meters primarily located indoors or outdoors? How many percentage of meters are installed indoors or outdoors?	About 50/50 located inside and outside.
6	Are any meters located in pits or vaults? If so, what are the percentages of meters installed in pits or vaults?	No vaults, meters to be replaced will either be inside the home or in a meter pit.
7	Are meters installed inline or on setters? How many percentage of meters are installed inline or on setters.	Mostly inline but there may be some setters.
8	Are Meter Interface Units (MIUs) required to be replaced?	The transponders will need to be replaced with the meters.
9	Are there any other components, such as check valves, curb stops, meter boxes & lids that need to be installed or replaced?	Possibly meter lids need to be replaced and if any damage is caused in the process of replacement, contractor provided plumber must repair/replace accordingly.
10	Are there language or cultural barriers anticipated in the community that require accommodation?	No, not really.
11	Is there a required resident notification protocol before and after replacement?	Yes, contractor will issue communications. Those communications are required to be approved by the District.
12	Are there risk-sharing provisions for delays caused by property owner unavailability or resistance?	Refer to the Service Agreement provided.
13	Is exit testing required for the old meters? If so, who provides it?	No
14	Are prevailing wages or Davis-Bacon wage rates required?	Project is not subject to Davis-Bacon wage requirements.
15	Is an engineering firm involved?	No
16	Will the project be phased geographically or based on risk prioritization?	Based on address list provided. We would recommend the contractor/service provider developing a plan for replacement.
17	Will we be provided with a map or list of addresses?	List of addresses.
18	What is the expected number of meter replacements per day or week?	That is at the contractors discretion based on the RFP and Service Agreement. There are time requirements and deadlines that must be adhere in the RFP and the Service Agreement. Please refer to those documents.
19	Are there any confined space entry requirements?	We do not expect any but that is the decision of the selected contractor/service provider.
20	Are there local permitting or inspection requirements the contractor should be aware of?	No